

ORDER NO. 122

**HAYS TRINITY GROUNDWATER §
CONSERVATION DISTRICT §**

AGREED ORDER
Residential Closed-loop Geothermal Well Installation

At its March 10, 2006 Board meeting, the Hays Trinity Groundwater Conservation District (the District) Board of Directors, considered the proposal from Mr. William Dunn (Owner/Applicant) for the installation of 5 closed loop geothermal wells, each to a depth of 300 feet, to serve the future residence located at 2950 Pump Station Road, Wimberley, TX. Mr. Dunn and the District stipulate as follows:

1. Before initiating any construction under this Agreed Order, the Applicant will register the project with the District. At the time of registration, the Applicant will remit payment of \$60.00 per well for a total of \$300.00.
2. The wells will be sealed over their entire length. All sealing materials must meet Texas Department of Licensing and Regulation standards for sealing materials.
3. Heat exchange fluid must be potable water.
4. Upon completion, the installer (i.e., a licensed well driller) shall submit to the District one log per each of the 5 wells, illustrating well construction.
5. This Agreed Order serves in lieu of an operating permit. The wells will be exempt from aquifer test requirement and well spacing rules.

SIGNED AND ENTERED THIS ____ DAY OF March, 2006.

**Andrew Backus
President
Hays Trinity Groundwater Conservation
District**

Attested by:

I, the undersigned, have read and understand the foregoing Agreed Order. I agree to the terms and conditions specified herein.

William Dunn, owner

Date: _____